

Annexure C


File No: 657

Date : 02/02/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Venkatesh .H, Technical Manager from R.D.W & S.D Water testing Lab, Tumkur-572102 inspected the GREEN WOOD INTERNATIONAL SCHOOL, Benachigere Gate, N.H. 206, Nittur Hobli, Gubbi Taluk, Tumkur-572223 on 29/10/2025 and on the basis of Water Test Report (Attached) bearing sample code no. TUM25OCT2964 dated 30/10/2025 of R.D.W & S.D Water testing Lab, Tumkur-572102 certified that the GREEN WOOD INTERNATIONAL SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate Valid for a period of **One Year term from the Date of Issue.**


ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್
ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು
ಸೇವೆಗಳ ಉಪ ವಿಭಾಗ, ಗುಬ್ಬಿ.

Signature with seal :

Name : M. Nagendraappa.....

Designation : Assistant Executive Engineer

Name & Address of department/office

AEE RDWS Subdivision Gubbi

To


GREEN WOOD INTERNATIONAL SCHOOL

Benachigere Gate, N.H. 206, Nittur Hobli

Gubbi Taluk, Tumkur District

Pincode-572223


PRINCIPAL
GREEN WOOD INTERNATIONAL SCHOOL
Benachigere Gate, N.H. 206,
Nittur Hobli, Gubbi-572 216


SECRETARY
GREEN WOOD INTERNATIONAL SCHOOL
Benachigere Gate, N.H. 206,
Nittur Hobli, Gubbi-572 216



Tumkur District Water Quality Testing Laboratory

TC- 14841

Zilla Panchayath Compound B.H Road Tumkur - 572101, Karnataka.

Email: rdwsd.wqmsp.tumkurdistrictlab@gmail.com

TEST REPORT

Green Wood International School
Benachigere Gate,
NH 206, Nittur Hobli,
Gubbi-572223
Tumkur District
Contact No : 9148040875

Sample Collected By: Customer

Reference: TRF

Sample code:TUM25OCT2964

ULR No. : TC- 148412500002964F

Date of Sample collection:29/10/2025

Sample receipt date:29/10/2025

Analysis start date:30/10/2025

Analysis completion date: 30/10/2025

Report date: 30/10/2025

Sampling Method: APHA24th Edition

Sample Particulars : Drinking Water

Sample quantity:1 Liter

Sl. No	Test	Test Method	Detectable Limit	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012 RA-2018	Results	Units
Description: Colourless liquid.							
1.	pH Value at 23.8°C	IS 3025 (Part-11) : 2022	2-14	6.5 – 8.5	No relaxation	6.58	-
2.	Electrical Conductivity, at 24.1°C	IS 3025 (Part-14) :2019	1.0	-	-	79	µS/cm
3.	Odour	IS 3025 (Part-5 & 6):2018	-	Agreeable	Agreeable	Agreeable	-
4	Taste	IS 3025 (Part-7 & 8):2023	-	Agreeable	Agreeable	-	-
5.	Colour	IS 3025 (Part-4) :2023	1	5	15	<1	Hz
6.	Turbidity	IS 3025 (Part-10) : 2023	0.5	1	5	<0.5	NTU
7.	Total Dissolved Solids @ 180°C	IS 3025 (Part-16) : 2023	16	500	2000	48	mg/l
8.	Alkalinity as CaCO ₃	IS 3025 (Part-23) : 2023	20	200	600	22	mg/l
9.	Total Hardness as CaCO ₃	IS 3025 (Part-21) : 2019	20	200	600	24	mg/l
10.	Calcium as Ca	IS 3025 (Part-40) : 2024	8.0	75	200	<8	mg/l
11.	Magnesium as Mg	IS 3025 (Part-46) : ,2023	5.0	30	100	<5	mg/l
12	Chloride as Cl	IS 3025 (Part-32) : 2019	10	250	1000	15	mg/l
13.	Sulphate as SO ₄	IS 3025 (Part-24/Sec 1) : 2022	1.0	200	400	3	mg/l
14.	Fluoride as F, mg/l	APHA 24 th Edition 4500- F D	0.1	1	1.5	<0.1	mg/l
15.	Nitrate as NO ₃ , mg/l	APHA 24 th Edition 4500- NO ₃ B	1.0	45	No relaxation	<1.0	mg/l
16.	Iron as Fe, mg/l	IS 3025 (Part-53) : 2024	0.1	1	No relaxation	<0.1	mg/l

Reviewed & Authorized By

Venkatesh.H
Technical Manager

RDWSD/WQMSP/TeR/01

R.D.W & S.D.
Water Testing Lab
TUMKUR-572102.

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full, without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 7 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

-: End of Report:-